




**DELHI JAL BOARD: GNCTD
CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54**

**TEST REPORT**

THE REPORT PERTAINS TO THIS PARTICULAR SAMPLE ONLY

Sample ID	Ref.No. D.J.B/DTQC/Wzd./2022/paid-101-102		
Location /Address of Sample	The Smarth School Main Wazirabad Road, East of Loni Road Delhi-93		
Name of Work	--		
Reference No.	TSSWR /2022-23/071	Ref. Letter Date	19.07.2022
Challan No.	139	Challan Date	21.07.2022
Sample Collection date	08.08.2022	Analysis date	09.08.2022
Any other Information	--	Reporting date	12.08.2022

TEST RESULTS

S.N.	Parameters	Unit	As per the IS 10500		1	2
			Desirable limit	Permissible limit		
1	Turbidity	NTU	1	5	1.83	0.89
2	pH Value	--	6.5-8.5	No relaxation	7.22	7.40
3	Colour	Pt-Co	5	15	Clear	Clear
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	µs/cm	-	-	354	745
6	Total Dissolved Solids	Mg/l	500	2000	230	484
7	Total Alkalinity as CaCO ₃	Mg/l	200	600	130	288
8	Total Hardness as CaCO ₃	Mg/l	200	600	118	298
9	Calcium as Ca	Mg/l	75	200	20.8	71.2
10	Magnesium as Mg	Mg/l	30	100	11.04	28.80
11	Ammonical-Nitrogen	Mg/l	NIL	0.5	ND	ND
12	Nitrate	Mg/l	--	45	7.43	8.79
13	Chlorides as Cl	Mg/l	250	1000	34	58
14	Fluoride as F	Mg/l	1.0	1.5	0.53	0.71
15	Sulphate as SO ₄	Mg/l	200	400	37.4	67.8
16	T. Iron	Mg/l	--	1.0	0.08	0.12
17	Residual Chlorine	Mg/l	0.2	1.0	0.50	ND
18	COLIFORM COUNT AT 37 ^o C	MPN/100 ml	Absent	--	0	0

.....End of Report.....

Remarks : : On the basis of above tested parameters, above water samples conform drinking Water Specification IS-10500 & can be considered fit for drinking purpose.

[Signature]
ACWA

Asst. Chief Water Analyst
D.J.B. (GNCTD) of Delhi
Water Works, Wazirabad

[Signature]
CHEMIST

[Signature]
A/CHEMIST

**MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DY. HEALTH OFFICER
SHAHDARA NORTH ZONE**

No. DHO/Shah (N)/2022/D-230

Dated: 30/7/22

SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary no. 913, dated 09.07.2022, the inspection of "THE SAMARTH SCHOOL" at Main Wazirabad Road, East of Loni Road, Delhi-110093 was carried out on dated 13.07.2022. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant
"PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF



Municipal Corporation of Delhi
Office of the Executive Engineer (M)-III
Shahdara North Zone
L.I.G. Flats, East of Loni Road, Shahdara, Delhi-93



No. AE/M/III/SH/N/2022-23/D- 40

Dated...21.10.22.....

To,


**The Head of School,
The Samarth School,
(Formerly known as Siddharth International Public School)
Pocket-B, East of Loni Road,
Main Wazirabad Road,
Delhi – 110093**

SUBJECT:- SCHOOL BUILDING FITNESS CERTIFICATE.

In reference to your letter No. TSSWR/2022/23/64 dated 08.07.2022 on the above cited subject, this is to certify that The Samarth School, Main Wazirabad Road, Pocket-B, East of Loni Road, Delhi - 110093 has been inspected by the area Junior Engineer and visually building was found in satisfactory condition at present.

This certificate has no bearing over status of colony, land use & unauthorized construction if any. School authorities will have to follow rules & regulations issued from different agencies time to time.

This certificate is valid for One Year.


**Assistant Engineer, M-III
Shahdara North Zone**



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/NDZ/ 1285

Dated: 30/11/2022

FIRE SAFETY CERTIFICATE

Certified that The Samarth School (Earlier it was Siddharth International Public School), located at Opp. Pocket- B, East Loni Road, Delhi-110093, comprised of Ground + Three Upper Floors only owned / occupied by The Samarth School, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/NDZ/2052 Dated 25/10/19. The School building was re-inspected by the officer concerned of this department on 16/11/2022 in presence of Sh. Rajnish Gupta (Administrator) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with D.O.E. Circular No. 262-362 Dated 17/01/2005 and observed that the building is fit for occupancy class "Educational" (Group-B) with effect from 30/11/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 30/11/2022 at New Delhi by.

Riv
30/11/22
(S.K.DUA)

**Dy. CHIEF FIRE OFFICER.
DELHI FIRE SERVICE**

Copy to :-

1. The Principal, The Samarth School (Earlier it was Siddharth International Public School), Opp. Pocket- B, East Loni Road, Delhi-110093.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-11053.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.