



Annexure - 01

7-275
Asst. Secy.
Delhi Fire Service

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2023/NDZ/177

Dated: 23/01/2023

FIRE SAFETY CERTIFICATE

Certified that The Samarth School (Earlier it was Siddharth International Public School), located at Opp. Pocket- B Park, Gurudwara Road Dilshad Garden, Delhi-110095, comprised of Ground & Three Upper Floors only owned / occupied by The Samarth School, was earlier issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/NDZ/1867 Dated 27/09/19. The School building was re-inspected by the officer concerned of this department on 18/01/2023 in presence of **Smt. Geetika Bansal (Vice-Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied rule 33 of the Delhi Fire Service Rule, 2010 and observed that the building is fit for occupancy class "Educational" (Group-B) with effect from 23/01/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 23/01/2023 at New Delhi by


(S.K. DUA)

**DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

Copy to: -

- o/c*
1. The Principal, The Samarth School (Earlier it was Siddharth International Public School), Opp. Pocket- B Park, Gurudwara Road Dilshad Garden, Delhi-110095
 2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-11053

Conditions for the validity of Fire Safety Certificate:

1. Applicant has given an undertaking dated 17/01/2023 that he will not use newly constructed rooms on 3rd floor and will re-apply before use, failing which NOC / FSC will be treated null and void.
2. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in.